



## PD10 & PD100F-CU Specification Sheet

### Snow Guards

#### Part 1 – GENERAL

##### 1.1 SUMMARY

###### A. WORK INCLUDES

1. PD10 & PD100F gusseted snow guards that attach directly to roof deck.
2. Coordinate with roof installation to assure proper placement of snow guards.
3. Provide appropriate fasteners for snow guard & roof system.

###### B. RELATED SECTIONS

1. Section 076000: Flashing and Sheet Metal	MasterFormat 2016 07 60 00
2. Section 073100: Shingles and Shakes	MasterFormat 2016 07 31 00
3. Section 073200: Roof Tiles	MasterFormat 2016 07 32 00
4. Section 077253: Snow Guards	MasterFormat 2016 07 72 53

##### 1.2 SYSTEM DESCRIPTION

###### A. COMPONENTS

1. PD10 & PD100F-CU snow guard systems consist of individual metal snow guards.
2. Fasteners
  - a. To be of metal compatible with snow guards.
  - b. Fasteners should be selected for compatibility with roof deck.
  - c. Fastener strength should exceed or be equal to snow guard system.

###### B. DESIGN REQUIREMENTS

1. Spacing to be recommended by manufacturer or building engineer.
2. Minimum 2 fasteners per snow guard.
3. It is important to design new structures or assess existing structures to make sure they can withstand retained snow loads.

##### 1.3 SUBMITTAL

- A. Submit manufacturer's specifications, standard detail drawings, installation instructions, and recommended layout.

##### 1.4 QUALITY ASSURANCE

- A. Installer to be experienced in installation of specified roofing material & snow guards for not less than 5 years in the area of the project.

##### 1.5 DELIVERY / STORAGE / HANDLING

- A. Inspect material upon delivery & order replacements for any missing or defective items. Keep material dry, covered & off the ground until installed.



## PD10 & PD100F-CU Specification Sheet Snow Guards

### **Part 2 – PRODUCTS**

#### 2.1 MANUFACTURER

A. Alpine SnowGuards®, a Division of Vermont Slate & Copper Services, Inc.  
289 Harrel St. Morrisville, VT 05661 | 888-766-4273 | [www.alpinesnowguards.com](http://www.alpinesnowguards.com)

#### 2.2 MATERIALS

- A. Aluminum – .032 aluminum.
- B. Copper – 16oz copper (strap, cap & gusset). Fleur-de-lis embellishment is *only* available in copper & has a minimum material thickness of .040.
- C. Freedom Gray™ – 16oz tin-zinc coated copper.
- D. Lead-Coated Copper – 16oz lead-coated copper.
- E. Rheinzink® – .8mm Rheinzink®.

#### 2.3 FINISH (choose one)

- A. Mill Finish – standard.
- B. Powder Coated – aluminum only. Available at additional cost.
- C. Kynar 500® pre-painted coil – aluminum only.

### **Part 3 – EXAMINATION**

#### 3.1 EXAMINATION

##### A. SUBSTRATE

1. Inspect structure on which snow guard system is to be installed and verify it will withstand any additional loading that it may incur. Notify general contractor of any deficiencies before installing Alpine SnowGuards' products.
2. Verify roofing material has been installed correctly prior to installing snow guards.

#### 3.2 INSTALLATION

1. Comply with architectural drawings and snow guard manufacturer's recommendations for location of system. Comply with manufacturer's written installation instructions for installation and layout.

Document Version 04.26.2023

07 72 53 Snow Guards