



PP325 Pipe-Style Snow Guard Specification Sheet

PART 1 – GENERAL

1.1 SUMMARY

A. WORK INCLUDES

1. PP325 Snow guard that attaches directly to roof deck.
2. Coordinate with installation of roof to assure proper placement of snow guards.
3. Provide appropriate snow guard and fasteners for roof system

B. RELATED SECTIONS

1. Section 07600: Flashing and Sheet Metal. MasterFormat 2004 07 60 00
2. Division 7: Thermal and Moisture Protection.

1.2 SYSTEM DESCRIPTION

A. COMPONENTS

1. PP325 Snow guard system consists of snow guard bracket and base plate with (2) stainless steel nuts and (2) bonded stainless steel and EPDM washers.
2. PP75, tubing (Snow Fence).
3. Couplings.
 - a. PP84, external
 - b. PP86, internal
4. PP56, end caps.
5. PP65, end collars.
6. PP95, ice flags, optional.
7. PP98, ice screen.
8. Fasteners
 - a. To be of metal compatible with snow guards.
 - b. Fasteners should be selected for compatibility with roof deck.
 - c. Fastener strength should exceed or be equal to that of snow guard system.

B. DESIGN REQUIREMENTS

1. Spacing to be recommended by manufacturer or building engineer.
2. Install a minimum of (4) fasteners per snow guard.
3. It is important to design new structures or assess existing structures to make sure they can withstand retained snow loads

1.3 SUBMITTAL

- A. Submit manufacturer's specifications, standard detail drawings, installation instructions, and recommended layout.

1.4 QUALITY ASSURANCE

- A. Installer to be experienced in installation of specified roofing material and snow guards for not less than 5 years in the area of the project.

1.5 DELIVERY / STORAGE / HANDLING

- A. Inspect material upon delivery and order replacements for any missing or defective items. Keep material dry, covered and off the ground until installed.



PP325 Pipe-Style Snow Guard Specification Sheet

PART 2 – PRODUCTS

2.1 MANUFACTURER

A. Alpine SnowGuards®, a Division of Vermont Slate & Copper Services, Inc.
289 Harrel St., Morrisville, VT 05661 | 888-766-4273 | www.alpinesnowguards.com

2.2 MATERIALS

A. Snow guard bracket (choose one)

1. 3/16" thick 5000 Series Aluminum.
2. 1/8" thick 304 Stainless.
3. 1/8" thick 260 Brass.

B. Base Plate – 11-gauge 304 stainless steel with (2) 5/16" 304 stainless steel machine screws welded into countersinks.

C. PP75, tubing (choose one)

1. Aluminum – 6000 Series, 1" outside diameter and .120" wall thickness, extruded.
2. Stainless Steel – 304 alloy, same dimensions as aluminum, welded.
3. Brass – 272 alloy 1" outside diameter and 1/8" wall thickness; 330 alloy upon request.

D. PP84 and PP86, external and internal couplings (choose one)

1. Aluminum – 6000 Series

- a. Internal and concealed coupling 3" long.
- b. External and exposed coupling which can also serve as a 5" long expansion mechanism .

2. Stainless Steel – 304 Series

- a. Internal and concealed coupling 3" long.
- b. External and exposed coupling which can also serve as a 5' long expansion mechanism.

3. Brass – 300 Series

- a. Internal and concealed coupling 3" long.
- b. C230 external and exposed coupling which can also serve as a 5" long expansion mechanism.

E. PP56, end caps (choose one)

1. 304 Stainless Steel.
2. Brass Plated Stainless Steel.

F. PP65, end collars (choose one)

1. 6000 Series Aluminum.
2. 304 Stainless Steel.
3. C230 Brass.

G. PP95, ice flags, optional, (choose one)

1. 6000 Series Aluminum 3" wide x length
2. 304 Stainless Steel.
3. 260 Brass.

H. Ice Screen (choose one)

1. 304 Stainless Steel.
2. 260 Brass.

I. Fasteners (can be purchased from others) to be compatible with chosen roof application and meet specified pull-out values as shown in load test data.



PP325 Pipe-Style Snow Guard Specification Sheet

2.3 FINISH (choose one)

- A. Mill Finish – standard
- B. Powder Coated – available at additional cost

PART 3 – EXECUTION

3.1 EXAMINATION

A. Substrate

1. Inspect structure on which snow guard system is to be installed and verify it will withstand any additional loading that it may incur. Notify general contractor of any deficiencies before installing Alpine SnowGuards' products.
2. Verify roofing material has been installed correctly prior to installing snow guards.

3.2 INSTALLATION

- A. Comply with architectural drawings and snow guard manufacturer's recommendations for location of system. Comply with manufacturer's written installation instructions for installation and layout.

Document Version 04.28.2021
07 72 53 Snow Guards